

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0811:130 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Federal Signal, 2645 Federal Signal Dr., University Pk, IL 60466-3195
Contact: Leonard Steinbeigle (708) 534-3400 FAX (708) 534-4878

DESIGN: Model *FSEX-HI strobe lights with clear lens *for use in hazardous locations: Class I, Division 1, Groups C and D; Class I, Division 2, Groups A and B; Class II, Groups E, F, G; and Class III. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Candela: 15 cd
Electrical: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application. Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated Type 4X. Refer to listee's Installation Instruction Manual for details.

*Rev. 02-03-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

FEBRUARY 3, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager